



IN THE ABSENCE OF BUILDING CODES OR OTHER REGULATIONS, MAINTAIN A MINIMUM DISTANCE OF FIVE FEET PLUS A SLOPE OF 45° FROM THE BOTTOM OF THE COMPACTED SUB-BASE TO THE BOTTOM OF THE ADJACENT STRUCTURE'S FOUNDATION, FOOTING OR PROPERTY LINE.

**BACKFILL MATERIAL REQUIREMENTS**

- PEA GRAVEL 1/8" ~ 3/4"
- CRUSHED ROCK 1/8" ~ 1/2"

**NOTE:**

THE INTENT OF THESE INSTRUCTIONS AND ILLUSTRATIONS IS TO HELP ENSURE THAT DAMAGE OR PREMATURE FAILURE TO THE LIFT STATION BASIN WILL NOT OCCUR. THIS INFORMATION IS NOT INTENDED TO PRECLUDE NORMAL SAFETY PROCEDURES AND REGULATIONS WHICH SHOULD BE FOLLOWED TO PREVENT INJURY TO PERSONNEL.

**SAFE INSTALLATION PROCEDURES SHALL BE ENTIRELY THE RESPONSIBILITY OF THE INSTALLER.**